

Pump Test Results Sheet

Date 23-Mar-04

Macipump

Type	300 Macipump 350		
Part No.			
Ser. No.			

Motor

Details	kW	7.5	rpm	960	FLC	15.5	Hz	50
Ser. No.	20087-H24597							

Site Specific (where appropriate)

Customer	Bondi Riamp		
SP No.			
Impeller	Dia	300	Depth

Noise Levels

LEQ		dBA
L Max		dBA
Peak		dBlin

Results

PSI	Head (M)	Motor (A)	Pumped Volume (litres)	Volume (m3)	Time (decimal minutes)	Time (sec)	Flow (lps)	Flow (m3/Hr)
3	2.11	15.10	448	0.45	0.29	17.40	25.75	92.69
7.5	5.27	14.50	448	0.45	0.35	21.00	21.33	76.80
12	8.44	13.40	448	0.45	0.52	31.20	14.36	51.69
Max	17.83	12.20	448	0.45	N/A	N/A	0.00	0.00

Max = Valve Closed

